





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

### АПвЭгаП-220 1x1200 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

For the cable of this mark correspond the foreign-made analogues:

NA2XS(FL)2Y (DE) · A2XS(FL)2Y (DE) · AHXCHBMK (FI) · AI/XLPE/CWS/LW/MDPE (GB) · XRUHAKXS (PL) · AΠβΠ2Γ (RU)

Technical cable requirements correspond to IEC 62067

Cables are used for laying:

- · in soil (trenches)
- · in damp, partially flooded premises
- · in ground with high humidity
- in non-navigable waters
- · in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЭгаП-П-220 1x1200/95 ТУ У 31.3-00214534-061:2008

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭгаП-220 1x1200/95 (ОМ) ТУ У 31.3-00214534-061:2008

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭгаП-220 1х1200/95 (г) ТУ У 31.3-00214534-061:2008







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭгаП-220 1x1200 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

### **TECHNICAL SPECIFICATIONS**

Rated voltage	kV	220
Maximum voltage	kV	252
Conductor rated area	mm²	1200
Minimum screen cross-section	mm²	95
Partial discharge factor for rated voltage, not more than	рC	6
Permissible short circuit current across the screen of	kA	19.3
minimum cross-section		
Maximum permissible short-circuit current in core	kA	113
Permissible continious current rating by aerial laying *		
in trefoil formation with double-side screen earthing	Α	1226
in trefoil formation with single-side screen earthing or	Α	1348
cross screen earthing		
plane with double-side screen earthing	Α	1185
plane with single-side screen earthing or cross screen	Α	1541
earthing		
Permissible continious current rating by burial *		
in trefoil formation with double-side screen earthing	Α	867
<ul> <li>in trefoil formation with single-side screen earthing or</li> </ul>	Α	995
cross screen earthing		
plane with double-side screen earthing	Α	755
plane with single-side screen earthing or cross screen	А	1050
earthing		
Maximum permissible conductor temperature		
Continious	°C	+90
in emergency operation	°C	+130
at short circuit	°C	+250
Operating temperature range	° C	-60 +50
Minimum bending radius by laying	mm	1776
Rated outer diameter of the cable (for reference) **	mm	111
Cable weight (approximate)	kg/km	13950
Malan		

#### Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

## АПвЭгаП-220 1x1200 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath



### **CONSTRUCTION**

- 1. Aluminium multiwire compacted conductor
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen with an integrated fiber-optic module (optional)
- 8. Lapping layer of semiconductive swellable tape
- 9. Alumopolymer tape
- 10. Outer sheath of polyethylene or polyethylene copolymer

Note: conductor segment twisting is not illustrated