





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

## ПвСП-220 1x500 ТУ У 31.3-00214534-061:2008

Power cables with copper conductor, XLPE-insulated, lead-sheathed, with outer sheath of polyethylene

Technical cable requirements correspond to IEC 62067

Cables are used for laying:

- · in places, where small mechanical impacts on cable are possible, including tensile forces
- · in soil (trenches) with high corrosiveness
- · in damp, partially flooded premises
- · in ground with high humidity
- · in wetlands
- · in non-navigable waters
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

 $\Pi$ вСП- $\Pi$ -220 1x500/95 ТУ У 31.3-00214534-061:2008

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

ПвСП-220 1х500/95 (ОМ) ТУ У 31.3-00214534-061:2008

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

ПвСП-220 1х500/95 (г) ТУ У 31.3-00214534-061:2008







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвСП-220 1x500 ТУ У 31.3-00214534-061:2008

Power cables with copper conductor, XLPE-insulated, lead-sheathed, with outer sheath of polyethylene

# **TECHNICAL SPECIFICATIONS**

| Rated voltage   | kV    | 220     |
|---|-------|---------|
| Maximum voltage   | kV    | 252     |
| Conductor rated area                                      | mm²   | 500     |
| Sheath thikness   | mm    | 3.3     |
| Partial discharge factor for rated voltage, not more than | рС    | 6       |
| Maximum permissible short-circuit current in core         | kA    | 71.5    |
| Permissible continious current rating by aerial laying *  |       |         |
| in trefoil formation with double-side screen earthing     | Α     | 922     |
| in trefoil formation with single-side screen earthing or  | Α     | 969     |
| cross screen earthing                                     |       |         |
| plane with double-side screen earthing                    | Α     | 925     |
| plane with single-side screen earthing or cross screen    | Α     | 1101    |
| earthing  |       |         |
| Permissible continious current rating by burial *         |       |         |
| in trefoil formation with double-side screen earthing     | А     | 705     |
| in trefoil formation with single-side screen earthing or  | Α     | 760     |
| cross screen earthing                                     |       |         |
| plane with double-side screen earthing                    | Α     | 636     |
| plane with single-side screen earthing or cross screen    | Α     | 799     |
| earthing  |       |         |
| Maximum permissible conductor temperature                 |       |         |
| Continious  | °C    | +90     |
| in emergency operation                                    | °C    | +130    |
| at short circuit  | °C    | +250    |
| Operating temperature range                               | °C    | -60 +50 |
| Minimum bending radius by laying                          | mm    | 2350    |
| Rated outer diameter of the cable (for reference) **      | mm    | 94      |
| Cable weight (approximate)                                | kg/km | 20720   |
| Natas   |       |         |

#### Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвСП-220 1x500 ТУ У 31.3-00214534-061:2008

Power cables with copper conductor, XLPE-insulated, lead-sheathed, with outer sheath of polyethylene



### **CONSTRUCTION**

- 1. Copper multiwire compact conductor
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Lapping layer of semiconductive tape
- 7. Lead sheath
- 8. Outer sheath of polyethylene or polyethylene copolymer