



## **АПвЕгПнг-6 3х300** **ТУ У 31.3-00214534-017-2003**

Power cables with aluminium conductors, flame-retardant, with XLPE, longitudinal screen sealing and polymer compound outer sheath

---

Technical cable requirements correspond to IEC 60502-2

---

Cables are used for laying:

- *in premises, tunnels, ducts, mines, dry soil and outdoor under shelter*
- *single laying*

---

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЕгПнг-П-6 3х300/25 ТУ У 31.3-00214534-017-2003

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

---

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЕгПнг-6 3х300/25 (ОМ) ТУ У 31.3-00214534-017-2003

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

---

It is possible to manufacture cable with sealed conductors.

Order entry example:

АПвЕгПнг-6 3х300/25 (г) ТУ У 31.3-00214534-017-2003

---

It is possible manufacturing of cables in versions (A) and (B), flame-retardant when laying in bunches

---

Fire safety code in accordance with ДСТУ 4809:2007: ПБ101122000

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *toxicity class Tk1 of the combustion products of nonmetallic elements (toxicity index from 13 up to 40 g/m<sup>3</sup>)*
- *class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m<sup>2</sup>/kg)*
- *class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)*
- *corrosive class Кк2 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH more than 4.3, specific conductivity less than 10 μS/mm)*



## АПвЕгПнг-6 3x300 ТУ У 31.3-00214534-017-2003

Power cables with aluminium conductors, flame-retardant, with XLPE, longitudinal screen sealing and polymer compound outer sheath

### TECHNICAL SPECIFICATIONS

|                                                                              |                 |                                               |
|------------------------------------------------------------------------------|-----------------|-----------------------------------------------|
| Rated voltage                                                                | kV              | 6                                             |
| Maximum voltage                                                              | kV              | 7.2                                           |
| Number and rated area of conductors                                          | mm <sup>2</sup> | 3 x 300                                       |
| Insulation thickness                                                         | mm              | 2.8                                           |
| Minimum screen cross-section                                                 | mm <sup>2</sup> | 25                                            |
| Permissible short circuit current across the screen of minimum cross-section | kA              | 5.1                                           |
| Maximum permissible short-circuit current in core                            | kA              | 28.2                                          |
| Permissible continuous current rating *                                      |                 |                                               |
| • by aerial laying                                                           | A               | 475                                           |
| • by burial                                                                  | A               | 384                                           |
| Partial discharge factor for rated voltage, not more than                    | pC              | 6                                             |
| Maximum permissible conductor temperature                                    |                 |                                               |
| • Continuous                                                                 | °C              | +90                                           |
| • in emergency operation                                                     | °C              | +130                                          |
| • at short circuit                                                           | °C              | +250                                          |
| Operating temperature range                                                  | °C              | -60 ... +50                                   |
| Minimum bending radius by laying                                             | mm              | 1264                                          |
| Rated outer diameter of the cable (for reference) **                         | mm              | 79                                            |
| Cable weight (approximate)                                                   | kg/km           | 7390                                          |
| Rated factory cable length and gross weight of the delivery on the drums *** | m, t            | # 25УД-90: 443 • 4.8<br># 26УД-100: 631 • 6.5 |

#### Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.5 °K • m/W, laying depth in the ground 0.8 m, shields are grounded at both ends of the line


\*\* The external diameter may differ from the rated up to ± 10 %

\*\*\* Отклонение фактической массы брутто от указанного значения может составлять ± 7 %



## АПвЕгПнг-6 3х300 ТУ У 31.3-00214534-017-2003

Power cables with aluminium conductors, flame-retardant, with XLPE, longitudinal screen sealing and polymer compound outer sheath



### CONSTRUCTION

**1. Aluminium multiwire compacted conductor**

*Note: It is possible to manufacture cable with sealed conductors.*

**2. Inner extruded semiconducting layer**

**3. XLPE insulation**

**4. Outer extruded semiconducting layer**

**5. Lapping layer of semiconductive swellable tape**

**6. Copper screen**

*Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor*

**7. Extruded filling of PVC compound**

**8. Flame-retardant polymer compound outer sheath**

*Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath*

*Note: Conductor twisting is not illustrated*