



## КВВГзнг 7х0.75 ТУ У 31.3-00214534-018-2003

Control flame-retardant cables with copper conductors, PVC compound insulation, PVC compound sheath

Cables are used for laying:

- *in premises, dry ducts and tunnels, in corrosive environment*
- *with no risk of mechanical damage in operation*
- *in bunches*

Fire safety code in accordance with ДСТУ 4809:2007: ПБ120000000

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *bunched cable flame retardance category A*

### TECHNICAL SPECIFICATIONS

|                                              |                 |            |
|----------------------------------------------|-----------------|------------|
| Rated voltage (AC / DC)                      | V               | 660 / 1000 |
| Number and rated area of conductors          | mm <sup>2</sup> | 7 x 0.75   |
| Minimum bending radius by laying             | mm              | 60         |
| Cable outer diameter (for reference only) ** | mm              | 10         |
| Cable weight (approximate)                   | kg/km           | 150        |

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

\*\* The external diameter may differ from the rated up to  $\pm 10\%$

### CONSTRUCTION

1. Copper conductor
2. PVC compound insulation
3. Low flammable PVC compound outer sheath

Note: Conductor twisting is not illustrated

