





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭоВ(к)-6 3х70 ТУ У 31.3-00214534-017-2003

Three-core power cables with aluminium conductors, with XLPE, collective screen and PVC compound outer sheath

Technical cable requirements correspond to IEC 60502-2

Cables are used for laying:

- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- · single laying

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭоВ(к)-6 3х70/35 (ОМ) ТУ У 31.3-00214534-017-2003

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductors.

Order entry example:

АПвЭоВ(к)-6 3х70/35 (г) ТУ У 31.3-00214534-017-2003

Fire safety code in accordance with ДСТУ 4809:2007: ΠБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭоВ(к)-6 3х70 ТУ У 31.3-00214534-017-2003

Three-core power cables with aluminium conductors, with XLPE, collective screen and PVC compound outer sheath

### **TECHNICAL SPECIFICATIONS**

| Rated voltage   | kV    | 6                     |
|---|-------|-----------------------|
| Maximum voltage   | kV    | 7.2                   |
| Number and rated area of conductors                         | mm²   | 3 x 70                |
| Insulation thikness   | mm    | 2.5                   |
| Minimum screen cross-section                                | mm²   | 35                    |
| Permissible short circuit current across the screen of      | kA    | 7.1                   |
| minimum cross-section                                       |       |                       |
| Maximum permissible short-circuit current in core           | kA    | 6.6                   |
| Permissible continious current rating *                     |       |                       |
| by aerial laying  | Α     | 196                   |
| • by burial   | Α     | 171                   |
| Partial discharge factor for rated voltage, not more than   | рС    | 6                     |
| Maximum permissible conductor temperature                   |       |                       |
| Continious  | °C    | +90                   |
| in emergency operation                                      | °C    | +130                  |
| • at short circuit  | °C    | +250                  |
| Operating temperature range (in climate version NF)         | °C    | -50 +50               |
| Operating temperature range (in climate version T)          | °C    | -25 +65               |
| Minimum bending radius by laying                            | mm    | 768                   |
| Rated outer diameter of the cable (for reference) **        | mm    | 48                    |
| Cable weight (approximate)                                  | kg/km | 2770                  |
| Rated factory cable length and gross weight of the delivery | m, t  | # 18аУД-40: 710 • 2.5 |
| on the drums ***  |       | # 22УД-60: 814 • 3.2  |
|   |       | # 25УД-90: 1366 • 5.4 |
|   |       |                       |

#### Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.5 °K • m/W, laying depth in the ground 0.8 m, shields are grounded at both ends of the line

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %

<sup>\*\*\*</sup> Отклонение фактической массы брутто от указанного значения может составлять ± 7 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭоВ(к)-6 3х70 ТУ У 31.3-00214534-017-2003

Three-core power cables with aluminium conductors, with XLPE, collective screen and PVC compound outer sheath



### **CONSTRUCTION**

- 1. Aluminium multiwire compacted conductor
  Note: It is possible to manufacture cable with sealed conductors.
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Interstitial filler with polypropylene bundles
- 7. Lapping layer of semiconductive swellable tape
- 8. Copper screen
- 9. Lapping layer of synthetic paper
- 10. PVC compound outer sheath

Note: Conductor twisting is not illustrated