





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

### АПвЭСПу-10 1x300 ТУ У 27.3-00214534-092:2016

Single-core power cables with aluminium conductors, XLPE-insulated, with copper screen, lead-sheathed, with reinforced outer sheath of polyethylene

Technical cable requirements correspond to IEC 60502-2

Cables are used for laying:

- in places, where small mechanical impacts on cable are possible, including tensile forces
- · in soil (trenches) with high corrosiveness
- · in damp, partially flooded premises
- · in wetlands
- · in non-navigable waters
- · on difficult route sections, according to the unique specification
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЭСПу-П-10 1x300/25 ТУ У 27.3-00214534-092:2016

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭСПу-10 1х300/25 (ОМ) ТУ У 27.3-00214534-092:2016

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

Cables without copper screen can also be manufactured

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭСПу-10 1х300/25 (г) ТУ У 27.3-00214534-092:2016







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭСПу-10 1х300 ТУ У 27.3-00214534-092:2016

Single-core power cables with aluminium conductors, XLPE-insulated, with copper screen, lead-sheathed, with reinforced outer sheath of polyethylene

### **TECHNICAL SPECIFICATIONS**

Maximum voltagekV12Number and rated area of conductorsmm²1 x 300Insulation thiknessmm3.4Sheath thiknessmm1.8Permissible short circuit current across the screenkA8.90Maximum permissible short-circuit current in corekA28.2Permissible continious current rating *. by aerial laying in trefoil formationA577• by aerial flat layingA677• by burial in trefoil formationA414• by burial flatA419Partial discharge factor for rated voltage, not more thanpC6
Insulation thikness mm 3.4 Sheath thikness mm 1.8 Permissible short circuit current across the screen kA 8.90 Maximum permissible short-circuit current in core kA 28.2 Permissible continious current rating *  • by aerial laying in trefoil formation A 577  • by aerial flat laying A 677  • by burial in trefoil formation A 414  • by burial flat A 419
Sheath thiknessmm1.8Permissible short circuit current across the screenkA8.90Maximum permissible short-circuit current in corekA28.2Permissible continious current rating *• by aerial laying in trefoil formationA577• by aerial flat layingA677• by burial in trefoil formationA414• by burial flatA419
Permissible short circuit current across the screen kA 8.90  Maximum permissible short-circuit current in core kA 28.2  Permissible continious current rating *  • by aerial laying in trefoil formation A 577  • by aerial flat laying A 677  • by burial in trefoil formation A 414  • by burial flat A 419
Maximum permissible short-circuit current in core kA 28.2  Permissible continious current rating *  • by aerial laying in trefoil formation A 577  • by aerial flat laying A 677  • by burial in trefoil formation A 414  • by burial flat A 419
Permissible continious current rating *  • by aerial laying in trefoil formation  • by aerial flat laying  A 577  • by aerial flat laying  A 677  • by burial in trefoil formation  A 414  • by burial flat  A 419
<ul> <li>by aerial laying in trefoil formation</li> <li>by aerial flat laying</li> <li>by burial in trefoil formation</li> <li>by burial flat</li> <li>A 414</li> <li>by burial flat</li> <li>A 419</li> </ul>
<ul> <li>by aerial flat laying</li> <li>by burial in trefoil formation</li> <li>by burial flat</li> <li>A 414</li> <li>By burial flat</li> <li>A 419</li> </ul>
<ul> <li>by burial in trefoil formation</li> <li>by burial flat</li> <li>A 414</li> <li>A 419</li> </ul>
• by burial flat A 419
•
Partial discharge factor for rated voltage not more than pC 6
Tartar alconarge ractor for rated voltage, not more than
Maximum permissible conductor temperature
• Continious °C +90
• in emergency operation °C +130
• at short circuit °C +250
Operating temperature range °C -60 +50
Minimum bending radius by laying mm 1100
Rated outer diameter of the cable (for reference) ** mm 44
Cable weight (approximate) kg/km 4490
Rated factory cable length and gross weight of the delivery m, t # 18аУД-40: 879 • 4.5
on the drums *** # 22УД-60: 882 • 4.9
# 20aУД-60: 995 • 5.2

#### Notes

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, thermal resistivity of soil 1.5 °K•m/W, laying depth in the soil 0.8 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side, shields are earthed on both ends of the line

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %

<sup>\*\*\*</sup> Отклонение фактической массы брутто от указанного значения может составлять ± 7 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# АПвЭСПу-10 1х300 ТУ У 27.3-00214534-092:2016

Single-core power cables with aluminium conductors, XLPE-insulated, with copper screen, lead-sheathed, with reinforced outer sheath of polyethylene



### **CONSTRUCTION**

1. Aluminium multiwire compacted conductor

Note: It is possible to manufacture cable with sealed conductor.

- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Copper screen

Note: Cables without copper screen can also be manufactured

- 7. Lapping layer of semiconductive swellable tape
- 8. Lapping layer of semiconductive tape
- 9. Lead sheath
- 10. Strengthened polyethylene outer sheath

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath