





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвСПу-45 1x185 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in places, where small mechanical impacts on cable are possible, including tensile forces
- · in soil (trenches) with high corrosiveness
- · in damp, partially flooded premises
- · in wetlands
- · in non-navigable waters
- · on difficult route sections, according to the unique specification
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвСПу-П-45 1х185/95 ТУ У 31.3-00214534-060:2011

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвСПу-45 1х185/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвСПу-45 1х185/95 (г) ТУ У 31.3-00214534-060:2011







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвСПу-45 1х185 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene

TECHNICAL SPECIFICATIONS

Maximum voltagekV52Conductor rated areamm²185Sheath thiknessmm2Partial discharge factor for rated voltage, not more thanpC6Permissible short circuit current across the screenkA7.80Maximum permissible short-circuit current in corekA17.5Permissible continious current rating by aerial laying *• in trefoil formation with double-side screen earthingA401			
Sheath thiknessmm2Partial discharge factor for rated voltage, not more thanpC6Permissible short circuit current across the screenkA7.80Maximum permissible short-circuit current in corekA17.5Permissible continious current rating by aerial laying *• in trefoil formation with double-side screen earthingA401	Maximum voltage	kV	52
Partial discharge factor for rated voltage, not more than pC 6 Permissible short circuit current across the screen kA 7.80 Maximum permissible short-circuit current in core kA 17.5 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 401	Conductor rated area	mm²	185
Permissible short circuit current across the screen kA 7.80 Maximum permissible short-circuit current in core kA 17.5 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 401	Sheath thikness	mm	2
Permissible short circuit current across the screen kA 7.80 Maximum permissible short-circuit current in core kA 17.5 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 401	Partial discharge factor for rated voltage, not more than	рС	6
Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 401	Permissible short circuit current across the screen	kA	7.80
• in trefoil formation with double-side screen earthing A 401	Maximum permissible short-circuit current in core	kA	17.5
_	Permissible continious current rating by aerial laying *		
in the fail forms at in a with a in all a single and a substantial	in trefoil formation with double-side screen earthing	Α	401
• In tretoil formation with single-side screen earthing or A 410	in trefoil formation with single-side screen earthing or	Α	410
cross screen earthing	cross screen earthing		
• plane with double-side screen earthing A 450	plane with double-side screen earthing	Α	450
• plane with single-side screen earthing or cross screen A 485	plane with single-side screen earthing or cross screen	Α	485
earthing	earthing		
Permissible continious current rating by burial *	Permissible continious current rating by burial *		
• in trefoil formation with double-side screen earthing A 338	in trefoil formation with double-side screen earthing	Α	338
• in trefoil formation with single-side screen earthing or A 346	in trefoil formation with single-side screen earthing or	Α	346
cross screen earthing	cross screen earthing		
• plane with double-side screen earthing A 335	plane with double-side screen earthing	Α	335
• plane with single-side screen earthing or cross screen A 361	 plane with single-side screen earthing or cross screen 	Α	361
earthing	earthing		
Maximum permissible conductor temperature	Maximum permissible conductor temperature		
• Continious °C +90	Continious		+90
• in emergency operation °C +130	in emergency operation		+130
• at short circuit °C +250	• at short circuit	° C	+250
Operating temperature range °C -60 +50	Operating temperature range	°C	-60 +50
Minimum bending radius by laying mm 1350	Minimum bending radius by laying	mm	1350
Rated outer diameter of the cable (for reference) ** mm 54	Rated outer diameter of the cable (for reference) **	mm	54
Cable weight (approximate) kg/km 6070	Cable weight (approximate)	kg/km	6070
Rated factory cable length and gross weight of the delivery m, t # 22УД-60: 635 • 4.8	Rated factory cable length and gross weight of the delivery	m, t	# 22УД-60: 635 • 4.8
on the drums *** # 25УД-90: 1068 • 8.1	on the drums ***		• •
# 26УД-100: **** 1347 • 10			# 26УД-100: **** 1347 • 10.
0			0

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %

^{***} Отклонение фактической массы брутто от указанного значения может составлять ± 7 %

^{****} Option delivery on not full drum








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвСПу-45 1x185 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- Note: It is possible to manufacture cable with sealed conductor.
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Lapping layer of semiconductive tape
- 7. Lead sheath
- 8. Strengthened polyethylene outer sheath

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath