





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭгаП-330 1x1000 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

For the cable of this mark correspond the foreign-made analogues:

NA2XS(FL)2Y (DE) • A2XS(FL)2Y (DE) • AHXCHBMK (FI) • AI/XLPE/CWS/LW/MDPE (GB) • XRUHAKXS (PL) • A Π B Π 2 Γ (RU)

Technical cable requirements correspond to IEC 62067

Cables are used for laying:

- · in soil (trenches)
- · in damp, partially flooded premises
- · in ground with high humidity
- · in non-navigable waters
- · in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cable with a segmented conductor

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЭгаП-П-330 1х1000/95 ТУ У 31.3-00214534-061:2008

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭгаП-330 1x1000/95 (ОМ) ТУ У 31.3-00214534-061:2008

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭгаП-330 1х1000/95 (г) ТУ У 31.3-00214534-061:2008







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭгаП-330 1x1000 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

TECHNICAL SPECIFICATIONS

Rated voltage	kV	330	
Maximum voltage	kV	363	
Conductor rated area	mm²	1000	
Minimum screen cross-section	mm²	95	
Partial discharge factor for rated voltage, not more than	рС	6	
Permissible short circuit current across the screen of	kA	19.3	
minimum cross-section			
Maximum permissible short-circuit current in core	kA	94	
Permissible continious current rating by aerial laying *			
 in trefoil formation with double-side screen earthing 	Α	995	
 in trefoil formation with single-side screen earthing or 	Α	1045	
cross screen earthing			
 plane with double-side screen earthing 	Α	999	
 plane with single-side screen earthing or cross screen 	Α	1189	
earthing			
Permissible continious current rating by burial *			
 in trefoil formation with double-side screen earthing 	Α	731	
 in trefoil formation with single-side screen earthing or 	Α	788	
cross screen earthing			
 plane with double-side screen earthing 	Α	662	
 plane with single-side screen earthing or cross screen 	Α	833	
earthing			
Maximum permissible conductor temperature			
Continious	° C	+90	
 in emergency operation 	° C	+130	
at short circuit	° C	+250	
Operating temperature range	° C	-60 +50	
Minimum bending radius by laying	mm	1856	
Rated outer diameter of the cable (for reference) **	mm	116	
Cable weight (approximate)	kg/km	14180	
Notes			

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭгаП-330 1x1000 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- It is possible to manufacture cable with a segmented conductor
- It is possible to manufacture cable with sealed conductor.
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen with an integrated fiber-optic module (optional)
- 8. Lapping layer of semiconductive swellable tape
- 9. Alumopolymer tape
- 10. Outer sheath of polyethylene or polyethylene copolymer

 Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath