



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвВГнг 4x2.5-1 ТУ У 31.3-00214534-018-2003



Power cables with copper conductors, XLPE-insulated, with low-flammable PVC-compound outer sheath

Cables are used for laying:

- in bunches
- in premises, dry ducts and tunnels, in corrosive environment

Fire safety code in accordance with <code>ДСТУ 4809:2007: ПБ120000000</code>

Products of this mark meet the requirements:

single wire cable flame retardance

bunched cable flame retardance category A

### **TECHNICAL SPECIFICATIONS**

Rated voltage	kV	1
Number and rated area of conductors	mm²	4 x 2.5
Phase insulation thikness	mm	0.7
Permissible continious current rating (AC of industrial frequency)	*	
• by aerial laying	А	31
• by burial	А	37
Maximum permissible conductor temperature		
Continious	°C	+90
in emergency operation	°C	+130
at short circuit	°C	+250
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	112.5
Rated outer diameter of the cable (for reference) **	mm	15
Cable weight (approximate)	kg/km	280
Rated factory cable length and gross weight of the delivery	m, t	# 12: 1450 · 0.5
on the drums ***		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated during operation in four-wire networks with load in all the conductors for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K • m/W, laying depth in the soil 0.7 m \*\* The external diameter may differ from the rated up to  $\pm$  10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвВГнг 4x2.5-1 ТУ У 31.3-00214534-018-2003

Power cables with copper conductors, XLPE-insulated, with low-flammable  $\ensuremath{\mathsf{PVC}}\xspace$  outer sheath



### CONSTRUCTION

- 1. Copper conductor
- 2. XLPE insulation
- 3. PVC compound belt insulation
- 4. Low flammable PVC compound outer sheath

Note: Conductor twisting is not illustrated

5 10